

A. Required water capacity & Fixed :
Installation for Building

1. Yard pillar hydrant 45,000Lts.
2. Wet Riser 45,000Lts.
3. First Aid hose Reel 2,000Lts.
4. Sprinkler System 80,000Lts.
5. Drenchers 45,000Lts.

B. Is generator required for Secondary : YES / NO
Power

18. Required Automatic Extinguishing : 1. Co2 Gas Installation
2. Foam Installations
3. Dry Chemical powder Installations

19. Required Automatic Detector system : 1. Heat Detector
2. Smoke Detector
3. Gas Detector

20. Required means of giving Alarm : YES / NO
warning

21. In access roadway required for pumping : YES / NO
and hydraulic flat form appliances

22. Required first Aid fire Extinguishers : YES / NO

23. Sky warning Lighting required : YES / NO

24. Any other requirements :
.....
.....
.....

Date :

.....
Signature of fire Prevention officer

Date :

.....
Signature of D.O.(Prevention)